



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
Fax: 0461-2352480
Email:ceo.ntpl@nlcindia.com, candp.ntpl@nlcindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

Due Date of Cover-I Opening : 09/11/2018 11:00:00 hrs. IST (Check NTPL eproc website for any change in due date of opening.)
Note : Quotation should be valid for 60 days from the date of opening.

Gentlemen,
 We shall be glad to receive your lowest online offer submitted through <http://eproc.ntplpower.com> for the material mentioned below, subject to our terms and conditions. Any other mode of offer will be rejected. Please indicate the enquiry number in all future correspondence. Offer details of the participating bidders will be available online after the tender is opened.

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity																										
1	<p align="center">विनिर्देश Specification</p> <p>93 046 0036 : Teflon insulated Cable, 2Cx0.5 sq.mm, Copper conductor for high temperature application</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> <tr><td>1</td><td>Conductor : Multistranded silver plated Copper to match 0.5 sq.mm</td></tr> <tr><td>2</td><td>Insulation : Wrapped and sintered Teflon with 0.25mm thickness</td></tr> <tr><td>3</td><td>Colour : Grey/Black</td></tr> <tr><td>4</td><td>Laying : All the cores laid up together</td></tr> <tr><td>5</td><td>Screening : SPC wire braid minimum 85% coverage</td></tr> <tr><td>6</td><td>Inner Sheath : Wrapped and sintered PTFE with 0.25 mm thickness</td></tr> <tr><td>7</td><td>Armouring : SS wire braid minimum 90% coverage</td></tr> <tr><td>8</td><td>Voltage grade : 600V, suitable for 260 degree C</td></tr> <tr><td>9</td><td>Length Per coil /reel : The cable shall be supplied in standard lengths of 500 meter, tolerance plus or minus 5 percent. However, Payment will be made for actual supplied length of each coil /reel, restricted to 1000 metres only. The tolerance mentioned is only for technical acceptance.</td></tr> </tbody> </table> <p align="center">वितरण अनुसूची Delivery Schedule</p> <table border="1"> <thead> <tr> <th>Delivery Type</th> <th>Period From PO Date (Days)</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>bulk supply</td> <td>1 to 90</td> <td>1000.0000</td> </tr> </tbody> </table> <p align="center">परीक्षण प्रमाणपत्र Test Certificate</p> <p>1. Original Test Certificate shall be furnished at free of cost with each consignment either from the Laboratories approved by BIS (or) from the Laboratories accredited by NABL (or) from Manufacturer, if the company is ISO Certified. 2. The firm should furnish a copy of current valid approval/accreditation for the laboratories, from where the test certificate is produced.</p>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	1	Conductor : Multistranded silver plated Copper to match 0.5 sq.mm	2	Insulation : Wrapped and sintered Teflon with 0.25mm thickness	3	Colour : Grey/Black	4	Laying : All the cores laid up together	5	Screening : SPC wire braid minimum 85% coverage	6	Inner Sheath : Wrapped and sintered PTFE with 0.25 mm thickness	7	Armouring : SS wire braid minimum 90% coverage	8	Voltage grade : 600V, suitable for 260 degree C	9	Length Per coil /reel : The cable shall be supplied in standard lengths of 500 meter, tolerance plus or minus 5 percent. However, Payment will be made for actual supplied length of each coil /reel, restricted to 1000 metres only. The tolerance mentioned is only for technical acceptance.	Delivery Type	Period From PO Date (Days)	Quantity	bulk supply	1 to 90	1000.0000	Metres	1000.0000
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)																												
1	Conductor : Multistranded silver plated Copper to match 0.5 sq.mm																												
2	Insulation : Wrapped and sintered Teflon with 0.25mm thickness																												
3	Colour : Grey/Black																												
4	Laying : All the cores laid up together																												
5	Screening : SPC wire braid minimum 85% coverage																												
6	Inner Sheath : Wrapped and sintered PTFE with 0.25 mm thickness																												
7	Armouring : SS wire braid minimum 90% coverage																												
8	Voltage grade : 600V, suitable for 260 degree C																												
9	Length Per coil /reel : The cable shall be supplied in standard lengths of 500 meter, tolerance plus or minus 5 percent. However, Payment will be made for actual supplied length of each coil /reel, restricted to 1000 metres only. The tolerance mentioned is only for technical acceptance.																												
Delivery Type	Period From PO Date (Days)	Quantity																											
bulk supply	1 to 90	1000.0000																											
2	<p align="center">विनिर्देश Specification</p>	Metres	1000.0000																										

एनटीपीएल स्टोर्स टुटिकोरिन में आपके प्रस्ताव को दरवाजा डिलीवरी आधार पर होना चाहिए।
 YOUR OFFER SHOULD BE ON DOOR DELIVERY BASIS AT NTPL STORES TUTICORIN
 निरीक्षण बंध /Inspection Clause : Inspection at Tuticorin
 गारंटी की आवश्यकताएँ /Guarantee Requirement : General Guarantee for Warranty as per NTPL format Warranty Period: 12 months from the date of commissioning or 18 months from the date of receipt of material, whichever is earlier.

संलग्नक Terms and Conditions of Enquiry
 Attachments :



NLC TAMILNADU POWER LIMITED
[A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
Fax: 0461-2352480
Email:ceo.ntpl@nclindia.com, candp.ntpl@nclindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity
93 046 0037 : Teflon insulated Cable, 4Cx0.5 sq.mm, Copper conductor for high temperature application			
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)		
1	Conductor : Multistranded silver plated Copper to match 0.5 sq.mm		
2	Insulation : Wrapped and sintered Teflon with 0.25mm thickness		
3	Colour : Grey/Black		
4	Laying : All the cores laid up together		
5	Screening : SPC wire braid minimum 85% coverage		
6	Inner Sheath : Wrapped and sintered PTFE with 0.25 mm thickness		
7	Armouring : SS wire braid minimum 90% coverage		
8	Voltage grade : 600V, suitable for 260 degree C		
9	Length Per coil /reel : The cable shall be supplied in standard lengths of 500 meter, tolerance plus or minus 5 percent. However, Payment will be made for actual supplied length of each coil /reel, restricted to 1000 metres only. The tolerance mentioned is only for technical acceptance.		
वितरण अनुसूची Delivery Schedule			
Delivery Type	Period From PO Date (Days)	Quantity	
bulk supply	1 to 90	1000.0000	
परीक्षण प्रमाणपत्र Test Certificate			
1. Original Test Certificate shall be furnished at free of cost with each consignment either from the Laboratories approved by BIS (or) from the Laboratories accredited by NABL (or) from Manufacturer, if the company is ISO Certified. 2. The firm should furnish a copy of current valid approval/accreditation for the laboratories, from where the test certificate is produced.			

मुख्य कार्यकारी अधिकारी के लिए - एनटीपीएल

For Chief Executive Officer- NTPL