



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
Fax: 0461-2352480
Email:ceo.ntpl@nlcindia.com, candp.ntpl@nlcindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

Due Date of Cover-I Opening : 19/11/2018 11:00:00 hrs. IST (Check NTPL eproc website for any change in due date of opening.)
Note : Quotation should be valid for 60 days from the date of opening.

Gentlemen,
 We shall be glad to receive your lowest online offer submitted through <http://eproc.ntplpower.com> for the material mentioned below, subject to our terms and conditions. Any other mode of offer will be rejected. Please indicate the enquiry number in all future correspondence. Offer details of the participating bidders will be available online after the tender is opened.

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity																
1	<p align="center">विनिर्देश Specification</p> <p>91 002 0006 : Variable Speed Fluid Coupling (Make : PREMIUM; Size - 20 SCR 25B or equivalent)</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> <tr> <td align="center">1</td> <td>Variable Speed Fluid Coupling PREMIUM Make ONLY - Size - 20 SCR 25B.</td> </tr> <tr> <td align="center">2</td> <td>Coupling Guard is to be supplied & assembled along with main supply.</td> </tr> <tr> <td align="center">3</td> <td>Adherence to IS Standards for DYNAMIC BALANCE TEST as per ISO 1940 to 2.5 gram.</td> </tr> <tr> <td align="center">4</td> <td>Conformance for ROUTINE RUN TEST</td> </tr> </tbody> </table> <p align="center">वितरण अनुसूची Delivery Schedule</p> <table border="1"> <thead> <tr> <th>Delivery Type</th> <th>Period From PO Date (Days)</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td align="center">BULK</td> <td align="center">0 to 90</td> <td align="center">2.0000</td> </tr> </tbody> </table> <p align="center">परीक्षण प्रमाणपत्र Test Certificate</p> <p>TEST CERTIFICATE is to be submitted along with the supply.</p>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	1	Variable Speed Fluid Coupling PREMIUM Make ONLY - Size - 20 SCR 25B.	2	Coupling Guard is to be supplied & assembled along with main supply.	3	Adherence to IS Standards for DYNAMIC BALANCE TEST as per ISO 1940 to 2.5 gram.	4	Conformance for ROUTINE RUN TEST	Delivery Type	Period From PO Date (Days)	Quantity	BULK	0 to 90	2.0000	Number	2.0000
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)																		
1	Variable Speed Fluid Coupling PREMIUM Make ONLY - Size - 20 SCR 25B.																		
2	Coupling Guard is to be supplied & assembled along with main supply.																		
3	Adherence to IS Standards for DYNAMIC BALANCE TEST as per ISO 1940 to 2.5 gram.																		
4	Conformance for ROUTINE RUN TEST																		
Delivery Type	Period From PO Date (Days)	Quantity																	
BULK	0 to 90	2.0000																	

NTPL RESERVES THE RIGHT TO CONDUCT REVERSE AUCTION ON ITEM WISE SITE COST BASIS AFTER PRICE BID OPENING SUBJECT TO ELIMINATION OF H1 BIDDER (HIGHEST QUOTE) IF THE QUALIFIED BIDDERS ARE MORE THAN FOUR.

एनटीपीएल स्टोर्स टुटिकोरिन में आपके प्रस्ताव को दरवाजा डिलीवरी आधार पर होना चाहिए।
 YOUR OFFER SHOULD BE ON DOOR DELIVERY BASIS AT NTPL STORES TUTICORIN
 निरीक्षण खंड /Inspection Clause : Inspection at Tuticorin
 गारंटी की आवश्यकताएँ /Guarantee Requirement : General Guarantee for Warranty, Bank Guarantee for Faithful Performace as per NTPL format Warranty Period: 12 months from the date of commissioning or 18 months from the date of receipt of material, whichever is earlier.COMBINED B.G. FOR FAITHFUL PERFORMANCE AND WARRANTY

संलग्नक
Attachments : Terms and Conditions of Enquiry