



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
 Fax: 0461-2352480
 Email:ceo.ntpl@nlcindia.com, candp.ntpl@nlcindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/NTPL/18-19/000448/C&P01(01) दिनांक/DATE :07/01/2019 पृष्ठ /Page - 1

Due Date of Cover-I Opening : 28/01/2019 11:00:00 hrs. IST (Check NTPL eproc website for any change in due date of opening.)
Note : Quotation should be valid for 60 days from the date of opening.

Gentlemen,
 We shall be glad to receive your lowest online offer submitted through <http://eproc.ntplpower.com> for the material mentioned below, subject to our terms and conditions. Any other mode of offer will be rejected. Please indicate the enquiry number in all future correspondence. Offer details of the participating bidders will be available online after the tender is opened.

| क्र.सं. SI No. | विवरण Details | माप की इकाई UOM | मात्रा Quantity | | | | | | | | | | | | | | | | | | | | |
|-------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------|------------------------------------|---|---------------------------------------------|---|----------------------------------------------------|---|--------------------------------------------------------------------|---|--------------------------------------|---|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---|------------------------------------------------------------------|---------------|----------------------------|----------|------|---------|--------|------|--------|
| 1 | <p align="center">विनिर्देश Specification</p> <p>91 221 0009 : 5 HP, 3 PHASE, 380 V - 440 V RANGE, 50 HZ, CENTRIFUGAL SELF PRIMING MONOBLOC PUMP SET WITH BASE PLATE.</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> <tr> <td align="center">1</td> <td>1. Make -LUBI, TEXMO, KSB, KIRLOSKAR, WPIL,</td> </tr> <tr> <td align="center">2</td> <td>2. Suction Head = -6 Mtr; Discharge Head = +10 Mtr</td> </tr> <tr> <td align="center">3</td> <td>3. Flow rate = Min of 10 m3/hr @ 15 M head to 50 m3/hr @ 10 M head</td> </tr> <tr> <td align="center">4</td> <td>4. Motor class of insulation-Class B</td> </tr> <tr> <td align="center">5</td> <td>5. Accessories: 1) 4 wheel mounted trolley- 1 No.; 2) 3" Inlet PVC flexible hose -6 Mtr; 3) 3" Outlet PVC flexible hose-10 Mtr; 4) 3" Hose collar -4 Numbers; 5) 3" Hose Clip-4 Nos.; 6) 3" Bend -2 Nos.; 7) 3" Foot valve-1 Nos.; 8) 5 HP starte-1 No.; 9) Suitable input cable -20 Mtr.</td> </tr> <tr> <td align="center">6</td> <td>Pump should be suitable for handling muddy water and oily water.</td> </tr> </tbody> </table> <p align="center">वितरण अनुसूची Delivery Schedule</p> <table border="1"> <thead> <tr> <th>Delivery Type</th> <th>Period From PO Date (Days)</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td align="center">bulk</td> <td align="center">0 to 60</td> <td align="center">2.0000</td> </tr> </tbody> </table> | क्र.सं. SI No. | तकनीकी कारक Technical Factor(s) | 1 | 1. Make -LUBI, TEXMO, KSB, KIRLOSKAR, WPIL, | 2 | 2. Suction Head = -6 Mtr; Discharge Head = +10 Mtr | 3 | 3. Flow rate = Min of 10 m3/hr @ 15 M head to 50 m3/hr @ 10 M head | 4 | 4. Motor class of insulation-Class B | 5 | 5. Accessories: 1) 4 wheel mounted trolley- 1 No.; 2) 3" Inlet PVC flexible hose -6 Mtr; 3) 3" Outlet PVC flexible hose-10 Mtr; 4) 3" Hose collar -4 Numbers; 5) 3" Hose Clip-4 Nos.; 6) 3" Bend -2 Nos.; 7) 3" Foot valve-1 Nos.; 8) 5 HP starte-1 No.; 9) Suitable input cable -20 Mtr. | 6 | Pump should be suitable for handling muddy water and oily water. | Delivery Type | Period From PO Date (Days) | Quantity | bulk | 0 to 60 | 2.0000 | Sets | 2.0000 |
| क्र.सं. SI No. | तकनीकी कारक Technical Factor(s) | | | | | | | | | | | | | | | | | | | | | | |
| 1 | 1. Make -LUBI, TEXMO, KSB, KIRLOSKAR, WPIL, | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 2. Suction Head = -6 Mtr; Discharge Head = +10 Mtr | | | | | | | | | | | | | | | | | | | | | | |
| 3 | 3. Flow rate = Min of 10 m3/hr @ 15 M head to 50 m3/hr @ 10 M head | | | | | | | | | | | | | | | | | | | | | | |
| 4 | 4. Motor class of insulation-Class B | | | | | | | | | | | | | | | | | | | | | | |
| 5 | 5. Accessories: 1) 4 wheel mounted trolley- 1 No.; 2) 3" Inlet PVC flexible hose -6 Mtr; 3) 3" Outlet PVC flexible hose-10 Mtr; 4) 3" Hose collar -4 Numbers; 5) 3" Hose Clip-4 Nos.; 6) 3" Bend -2 Nos.; 7) 3" Foot valve-1 Nos.; 8) 5 HP starte-1 No.; 9) Suitable input cable -20 Mtr. | | | | | | | | | | | | | | | | | | | | | | |
| 6 | Pump should be suitable for handling muddy water and oily water. | | | | | | | | | | | | | | | | | | | | | | |
| Delivery Type | Period From PO Date (Days) | Quantity | | | | | | | | | | | | | | | | | | | | | |
| bulk | 0 to 60 | 2.0000 | | | | | | | | | | | | | | | | | | | | | |

एनटीपीएल स्टोर्स टुटिकोरिन में आपके प्रस्ताव को दरवाजा डिलीवरी आधार पर होना चाहिए।
 YOUR OFFER SHOULD BE ON DOOR DELIVERY BASIS AT NTPL STORES TUTICORIN
 निरीक्षण बंध /Inspection Clause : Inspection at Tuticorin
 गारंटी की आवश्यकताएँ /Guarantee Requirement : Guarantee certificate for 1 year from manufacturer for pump & motor.

Basis of Evaluation : Item-wise.

संलग्नक Terms and Conditions of Enquiry
 Attachments :