



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
 Fax: 0461-2352480
 Email:ceo.ntpl@nlcindia.com, candp.ntpl@nlcindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/NTPL/19-20/000077/C&P01(01) दिनांक/DATE :06/05/2019 पृष्ठ /Page - 1

Due Date of receipt of Quotation on or before : 25/05/2019 15:00:00 hrs. IST (Check NTPL eproc website for any change in due date of opening.)
Note : Quotation should be valid for 60 days from the date of opening.

Gentlemen,
 We shall be glad to receive your lowest online offer submitted through <http://eproc.ntplpower.com> for the material mentioned below, subject to our terms and conditions. Any other mode of offer will be rejected. Please indicate the enquiry number in all future correspondence. Offer details of the participating bidders will be available online after the tender is opened.

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity	
1	विनिर्देश Specification	Number	2.0000	
	92 006 0412 : Siemens make 4000A, 3WL type, 3 Pole, Air Circuit Breaker			
	क्र.सं. SI No.			तकनीकी कारक Technical Factor(s)
	1			The Siemens Air Circuit Breaker shall be identical to the existing breaker in NTPL of ID No. 6641320218032.
	2			Siemens make 3WL type LT ACB of In shall be 4000A.
	3			The spring charging motor, closing and tripping coil voltage shall be 220VDC.
	4			Inspection shall be carried out in presence of NTPL staff. The Supplier shall provide necessary facilities for such inspection or test, at no extra cost to the purchaser. The Supplier shall give at least 15 days advance notice regarding the readiness of the ACB to the NTPL.
	5			Rack IN/OUT handle shall be provided for each breaker.
	वितरण अनुसूची Delivery Schedule			
	Delivery Type			Period From PO Date (Days)
Bulk	0 to 90	2.0000		
परीक्षण प्रमाणपत्र Test Certificate				
Test certificate is to be furnished along with supply.				
2	विनिर्देश Specification	Number	2.0000	
	92 006 0413 : Siemens make 2500A, 3WT type, 3 Pole, Air Circuit Breaker.			
	क्र.सं. SI No.			तकनीकी कारक Technical Factor(s)
	1			The Air Circuit Breaker shall be identical to the existing breaker in NTPL of ID No. 6640330221021.
	2			Siemens make 3WT type LT ACB of In shall be 2500A.
	3			The spring charging motor, closing and tripping coil voltage shall be 220VDC.

एनटीपीएल स्टोर्स टुटिकोरिन में आपके प्रस्ताव को दरवाजा डिलीवरी आधार पर होना चाहिए।
 YOUR OFFER SHOULD BE ON DOOR DELIVERY BASIS AT NTPL STORES TUTICORIN
 निरीक्षण खंड /Inspection Clause : NTPL Inspection Clause as per Annexure
 गारंटी की आवश्यकताएँ /Guarantee Requirement : General Guarantee for Warranty, Combined Bank Guarantee as per NTPL format - Warranty Period: 12 months from the date of commissioning or 18 months from the date of receipt of material, whichever is earlier.

Basis of Evaluation : Item-wise.

संलग्नक Terms and Conditions of Enquiry
 Attachments :



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
 Fax: 0461-2352480
 Email:ceo.ntpl@nclindia.com, candp.ntpl@nclindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/NTPL/19-20/000077/C&P01(01)

दिनांक/DATE
:06/05/2019

पृष्ठ /Page - 2

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity																		
4	Inspection shall be carried out in presence of NTPL staff. The Supplier shall provide necessary facilities for such inspection or test, at no extra cost to the purchaser. The Supplier shall give at least 15 days advance notice regarding the readiness of the ACB to the NTPL.																				
5	Rack IN/OUT handle shall be provided for each breaker.																				
वितरण अनुसूची Delivery Schedule																					
	Delivery Type	Period From PO Date (Days)	Quantity																		
	Bulk	0 to 90	2.0000																		
परीक्षण प्रमाणपत्र Test Certificate																					
Test certificate is to be furnished along with supply.																					
3	<p align="center">विनिर्देश Specification</p> <p>92 006 0414 : Siemens make 1600A, 3WT type, 3 Pole, Air Circuit Breaker.</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>The Air Circuit Breaker shall be identical to the existing breaker in NTPL of ID No. 6640320827040.</td> </tr> <tr> <td>2</td> <td>Siemens make 3WT type LT ACB of In shall be 1600A.</td> </tr> <tr> <td>3</td> <td>The spring charging motor, closing and tripping coil voltage shall be 220VDC.</td> </tr> <tr> <td>4</td> <td>Inspection shall be carried out in presence of NTPL staff. The Supplier shall provide necessary facilities for such inspection or test, at no extra cost to the purchaser. The Supplier shall give at least 15 days advance notice regarding the readiness of the ACB to the NTPL.</td> </tr> <tr> <td>5</td> <td>Rack IN/OUT handle shall be provided for each breaker.</td> </tr> </tbody> </table> <p align="center">वितरण अनुसूची Delivery Schedule</p> <table border="1"> <thead> <tr> <th>Delivery Type</th> <th>Period From PO Date (Days)</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>Bulk</td> <td>0 to 90</td> <td>4.0000</td> </tr> </tbody> </table> <p align="center">परीक्षण प्रमाणपत्र Test Certificate</p> <p>Test certificate is to be furnished along with supply.</p>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	1	The Air Circuit Breaker shall be identical to the existing breaker in NTPL of ID No. 6640320827040.	2	Siemens make 3WT type LT ACB of In shall be 1600A.	3	The spring charging motor, closing and tripping coil voltage shall be 220VDC.	4	Inspection shall be carried out in presence of NTPL staff. The Supplier shall provide necessary facilities for such inspection or test, at no extra cost to the purchaser. The Supplier shall give at least 15 days advance notice regarding the readiness of the ACB to the NTPL.	5	Rack IN/OUT handle shall be provided for each breaker.	Delivery Type	Period From PO Date (Days)	Quantity	Bulk	0 to 90	4.0000	Number	4.0000
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)																				
1	The Air Circuit Breaker shall be identical to the existing breaker in NTPL of ID No. 6640320827040.																				
2	Siemens make 3WT type LT ACB of In shall be 1600A.																				
3	The spring charging motor, closing and tripping coil voltage shall be 220VDC.																				
4	Inspection shall be carried out in presence of NTPL staff. The Supplier shall provide necessary facilities for such inspection or test, at no extra cost to the purchaser. The Supplier shall give at least 15 days advance notice regarding the readiness of the ACB to the NTPL.																				
5	Rack IN/OUT handle shall be provided for each breaker.																				
Delivery Type	Period From PO Date (Days)	Quantity																			
Bulk	0 to 90	4.0000																			