



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
 Fax: 0461-2352480
 Email:ceo.ntpl@nlcindia.com, candp.ntpl@nlcindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/NTPL/19-20/000095/C&P01(01) दिनांक/DATE :07/05/2019 पृष्ठ /Page - 1

Due Date of Cover-I Opening : 28/05/2019 15:00:00 hrs. IST (Check NTPL eproc website for any change in due date of opening.)
Note : Quotation should be valid for 60 days from the date of opening.

Gentlemen,
 We shall be glad to receive your lowest online offer submitted through <http://eproc.ntplpower.com> for the material mentioned below, subject to our terms and conditions. Any other mode of offer will be rejected. Please indicate the enquiry number in all future correspondence. Offer details of the participating bidders will be available online after the tender is opened.

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity																				
1	<p align="center">विनिर्देश Specification</p> <p>91 271 0026 : 150NB Sleeve coupling Gasket. MOC: Neoprene. Drawing No: Drg.NTPL/AHS/024/2016</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> <tr> <td align="center">1</td> <td>Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.</td> </tr> <tr> <td align="center">2</td> <td>MOC: Neoprene rubber with shore hardness of 65 +/- 5.</td> </tr> <tr> <td align="center">3</td> <td>The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.</td> </tr> </tbody> </table> <p align="center">वितरण अनुसूची Delivery Schedule</p> <table border="1"> <thead> <tr> <th>Delivery Type</th> <th>Period From PO Date (Days)</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td align="center">Sample</td> <td align="center">0 to 30</td> <td align="center">1.0000</td> </tr> <tr> <td align="center">Sample approval</td> <td align="center">31 to 35</td> <td align="center">0.0000</td> </tr> <tr> <td align="center">Bulk</td> <td align="center">36 to 60</td> <td align="center">349.0000</td> </tr> </tbody> </table> <p align="center">परीक्षण प्रमाणपत्र Test Certificate</p> <p>MATERIAL TEST CERTIFICATE FROM MANUFACTURER HAVING OWN ISO LAB OR GOVT ACCREDITED OR NABL ACCREDITED LAB OR GOV. LAB SHOULD BE FURNISHED ALONG WITH SUPPLY AT FREE OF COST.</p>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	1	Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.	2	MOC: Neoprene rubber with shore hardness of 65 +/- 5.	3	The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.	Delivery Type	Period From PO Date (Days)	Quantity	Sample	0 to 30	1.0000	Sample approval	31 to 35	0.0000	Bulk	36 to 60	349.0000	Number	350.0000
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)																						
1	Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.																						
2	MOC: Neoprene rubber with shore hardness of 65 +/- 5.																						
3	The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.																						
Delivery Type	Period From PO Date (Days)	Quantity																					
Sample	0 to 30	1.0000																					
Sample approval	31 to 35	0.0000																					
Bulk	36 to 60	349.0000																					
2	<p align="center">विनिर्देश Specification</p> <p>91 271 0027 : 200NB Sleeve coupling Gasket, MOC: Neoprene. Drawing No: Drg.NTPL/AHS/024/2016.</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> </tbody> </table>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	Number	500.0000																		
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)																						

एनटीपीएल स्टोर्स ट्युटोरिन में आपके प्रस्ताव को दरवाजा डिलीवरी आधार पर होना चाहिए।
 YOUR OFFER SHOULD BE ON DOOR DELIVERY BASIS AT NTPL STORES TUTICORIN
 निरीक्षण बंध /Inspection Clause : Inspection at Tuticorin
 गारंटी की आवश्यकताएँ /Guarantee Requirement : General Guarantee for Warranty as per NTPL format Warranty Period: 12 months from the date of commissioning or 18 months from the date of receipt of material, whichever is earlier.

Basis of Evaluation : Item-wise.

संलग्नक Attachments : 1)Drawing No:NTPL/AHS/024/2016;Sleeve Coupling Gasket
 2)Terms and Conditions of Enquiry



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) & TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate, Tuticorin-628004, Tamilnadu, India.

Phone: 0461-2352844, 2352840
 Fax: 0461-2352480
 Email: ceo.ntpl@nclindia.com, candp.ntpl@nclindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/NTPL/19-20/000095/C&P01(01)

दिनांक/DATE
:07/05/2019

पृष्ठ /Page - 2

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity
-------------------	------------------	--------------------	--------------------

1	Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.
2	MOC: Neoprene rubber with shore hardness of 65 +/- 5.
3	The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.

वितरण अनुसूची Delivery Schedule		
Delivery Type	Period From PO Date (Days)	Quantity
Sample	0 to 30	1.0000
Sample approval	31 to 35	0.0000
Bulk	36 to 60	499.0000

**परीक्षण प्रमाणपत्र
Test Certificate**

MATERIAL TEST CERTIFICATE FROM MANUFACTURER HAVING OWN ISO LAB OR GOVT ACCREDITED OR NABL ACCREDITED LAB OR GOV. LAB SHOULD BE FURNISHED ALONG WITH SUPPLY AT FREE OF COST.

3	<p align="center">विनिर्देश Specification</p> <p>91 271 0028 : 250NB Sleeve coupling Gasket. Moc: Neoprene.</p> <p>Drawing No: Drg.NTPL/AHS/024/2016</p> <table border="1"> <thead> <tr> <th>क्र.सं. SI No.</th> <th>तकनीकी कारक Technical Factor(s)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.</td> </tr> <tr> <td>2</td> <td>MOC: Neoprene rubber with shore hardness of 65 +/- 5.</td> </tr> <tr> <td>3</td> <td>The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.</td> </tr> </tbody> </table>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	1	Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.	2	MOC: Neoprene rubber with shore hardness of 65 +/- 5.	3	The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.	Number	520.0000
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)										
1	Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.										
2	MOC: Neoprene rubber with shore hardness of 65 +/- 5.										
3	The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.										

वितरण अनुसूची Delivery Schedule		
Delivery Type	Period From PO Date (Days)	Quantity
Sample	0 to 30	1.0000
Sample approval	31 to 35	0.0000
Bulk	36 to 60	519.0000

**परीक्षण प्रमाणपत्र
Test Certificate**

MATERIAL TEST CERTIFICATE FROM MANUFACTURER HAVING OWN ISO LAB OR GOVT ACCREDITED OR NABL ACCREDITED LAB OR GOV. LAB SHOULD BE FURNISHED ALONG WITH SUPPLY AT FREE OF COST.

4	<p align="center">विनिर्देश Specification</p> <p>91 271 0034 : 258 NB sleeve coupling gasket. MOC: Neoprene. Drawing No: DRG NO: NTPL/AHS/24/2016.</p>	Number	288.0000
---	--	--------	----------

मुख्य कार्यकारी अधिकारी के लिए - एनटीपीएल

For Chief Executive Officer- NTPL



NLC TAMILNADU POWER LIMITED
 [A JV between NLC India Ltd(formerly Neyveli Lignite Corporation Ltd) &TANGEDCO and subsidiary of NLC India Ltd]
Contracts & Purchase Division
Office of Chief Executive Officer
2x500 MW Thermal Power Plant,
Harbour Estate,Tuticorin-628004. Tamilnadu, India.

Phone: 0461-2352844, 2352840
 Fax: 0461-2352480
 Email:ceo.ntpl@nlcindia.com, candp.ntpl@nlcindia.com

CIN:
U40102TN2005GOI058050
GST NO.:
33AACCN3238N1ZD

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/NTPL/19-20/000095/C&P01(01)

दिनांक/DATE
:07/05/2019

पृष्ठ /Page - 3

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)		
1	Sleeve coupling gaskets shall be supplied as per Drg.NO: NTPL/AHS/24/2016.		
2	MOC: Neoprene rubber with shore hardness of 65 +/- 5.		
3	The insert seals shall be marked legibly and durably on the outer surface by Manufacturer trade mark with olimms code.		
वितरण अनुसूची Delivery Schedule			
	Delivery Type	Period From PO Date (Days)	Quantity
	Sample	0 to 30	1.0000
	Sample approval	31 to 35	0.0000
	Bulk	36 to 60	287.0000
परीक्षण प्रमाणपत्र Test Certificate			
MATERIAL TEST CERTIFICATE FROM MANUFACTURER HAVING OWN ISO LAB OR GOVT ACCREDITED OR NABL ACCREDITED LAB OR GOV. LAB SHOULD BE FURNISHED ALONG WITH SUPPLY AT FREE OF COST.			